

# Clean power delivers clean water

## Application Note



Power  
Quality  
Case  
Study



**Measuring tools:** Fluke 434 Power Quality Analyzer

**Features:** Power factor, harmonics

This story features a regional wastewater treatment plant on the shores of Puget Sound, Washington. An award-winning facility serving six cities, the plant processes an average of 21.1 million gallons of wastewater daily, with a daily capacity of up to 28.7 million gallons.

Most water treatment facilities use the same basic processes, but this one has been continuously updated since it opened in 1984, including high-intensity UV light and soon, a new Class "A" biosolids drying facility.

In this particular case, maintenance electrical specialist Mark Newport was in the process of installing new electronic power factor correction units at multiple motor control centers (MCCs) to improve power quality, protect equipment and reduce costs.

However, since corrective measures can often introduce new power quality problems into the system, he used a handheld Fluke 434 three-phase Power Quality Analyzer to make sure their efforts were successful.

### System details

The treatment plant relies on hundreds of motors, some as large as 500 hp. A SCADA control system is interfaced to the MCCs, as well as valves, actuators, sensors, and power monitors. It also allows instant visibility into the system at numerous stations.

If the plant went down for any reason, such as a regional power outage, sewage would continue to flow through the plant and through the sedimentation tanks, but it would be discharged into Puget Sound without full treatment.

To prevent this from ever happening, the plant electrical system has several levels of redundancy. It's served by dual utility feeds from two substations. Generally the load is shared between the two feeds, but either feed can handle the whole facility through a tie-breaker system. A 1.25 MW generator on an automatic transfer switch can take over within 8 seconds, if both utility feeds fail. Small, single-phase uninterruptible power supplies (UPS) maintain the elements of the redundant control system while the generator starts and synchs.

## Power correction

The power correction systems were being installed primarily to correct power factor. The same conductors were used to feed both adjustable-speed motor drives (ASDs) and across the line motor starters. The ASDs are non-linear loads and draw harmonic currents, especially at the fifth harmonic. Power factor capacitors present a lower impedance to higher frequencies, than to the 60 Hz fundamental. So a system with harmonic currents can cause overcurrent in correction capacitors. Maintenance staff at the plant realized this and decided to use a semiconductor-based device instead.




Figure 1. System connections.

The device they connected to each MCC continuously monitors a circuit's power factor. It generates leading reactive power (VAR's) to counteract the inductive, lagging VAR's from the motors. It can respond

instantly to load changes. In addition, it looks for any harmonic current and generates an inverted signal to cancel it. So, to any upstream devices it appears as if the MCC is a resistive load.

## What's power factor and why does it matter?

Power factor is a measurement that compares the real power (watts) being consumed to the apparent power (Volts-Amps) of the load. A purely resistive load would have a power factor of 1.0.

### What does it do?

The power available to perform work is called real power (kW). Inductive loads such as motors, transformers, and high-intensity lighting introduce reactive power (kVARs) into a power system. The system capacity is rated by the apparent power (kVA) which must be large enough to accommodate both the real power (kW) and reactive power (kVAR). Since reactive power requires system capacity, but performs no work, utilities charge more for it and plants try to keep net kVARs low. High reactive power translates to low power factor.

### Power factor facts:

- Utilities may charge higher rates or penalties for low power factor or high VARs.
- System capacity restrictions cause voltage drops and overheating.
- Inductive VARs can be corrected by applying capacitors or active conditioners.

### How much does poor PF cost?

#### Sample calculation

Assume the utility adds 1 % of demand charge for each 0.01 below PF of 0.97. Assume your PF averages 0.86 each month and your demand charge is \$7000.  $(0.97 - 0.86) * 100 \% = 11 \%$   
 $(11 \% \times \$7000) \times 12 \text{ months} = \$9,240$   
**avoidable annual cost**

### What to check?

- See if your utility rate plan imposes a charge for reactive demand or power factor.
- Find out how the utility measures power factor or VARs. For example, are they looking at peak intervals or averages?
- Identify loads that are causing lagging reactive power and develop a strategy for power factor correction.

### How much is OK?

To avoid paying higher utility fees, power factor should be higher than .97. Capacitors or conditioners may be applied on individual loads, at a confluence of several, or at the service entrance to improve power factor.

**Note:** This varies. Some utilities charge a rate for every percentage point between .85 and .97. Some charge a rate based on the number of VARs you use. Some don't charge at all.

### Before and after

The power correction system lived up to expectations. Six screens from the power quality analyzer tell the whole story.

The change in current is a real testimony to the impact of power factor correction. By correcting the power factor the rms current drawn by the MCC was reduced by 27 %. You can see what happens in the power measurements. The power conditioner uses a relatively small amount of power to run. But it counteracts the reactive power, and reduces the apparent power (kVA's) dramatically. You can see the power relationships in the vector diagrams below.

Prior to the installation, the upstream distribution equipment had to carry a lot of reactive current and harmonic current that was sloshing around without doing any real work. Now the system carries only hard-working current to the MCC's.

The power corrector cleaned up the harmonic content, too. Most of the non-linear load was from large motor drives. The 5th harmonic was a big contributor to the overall distortion. Both the amount of the 5th harmonic current and the current THD were cut by more than 50 %.

### Before


Power & Energy				
	L1	L2	L3	Total
kW	21.86	23.63	23.51	69.01
kVA	32.65	33.47	34.74	100.9
kVAR	24.25	23.70	25.57	73.61
PF	0.67	0.71	0.68	0.68
DPF	0.70	0.74	0.70	
A rms	118.4	121.6	126.3	
U rms	275.8	275.3	275.0	

### After

Power & Energy				
	L1	L2	L3	Total
kW	23.42	24.39	24.43	72.60
kVA	23.84	24.73	24.81	73.40
kVAR	3.73	3.41	3.57	10.84
PF	0.99	0.99	0.99	0.99
DPF	1.00	1.00	1.00	
A rms	85.7	89.3	89.5	
U rms	276.8	275.8	275.8	

**Figure 2 and 3: Power usage**

The Fluke 434 shows the power usage of the MCC with and without the power conditioner. Note the reductions in reactive power (kVAR), apparent power (kVA) and rms current (Arms). Power factor is ideal with the corrector activated.



**Figure 4:** Reactive (kVAR) vs. apparent (kVA) power.

### Before

HARMONICS TABLE				
VoIt	L1	L2	L3	N
THD%	2.0	2.3	2.0	71.4
H3%	0.9	0.8	0.6	5.9
H5%	1.4	1.9	1.5	5.3
H7%	0.6	0.7	0.6	4.8
Amp	L1	L2	L3	N
H3%	0.8	0.8	0.7	0.6
H5%	7.5	7.1	6.2	0.6
H7%	2.1	2.7	2.2	0.5


### After

HARMONICS TABLE				
VoIt	L1	L2	L3	N
THD%	2.2	2.3	2.2	68.7
H3%	0.8	0.7	0.6	5.2
H5%	1.8	1.9	1.7	5.6
H7%	0.7	0.9	0.8	5.2
Amp	L1	L2	L3	N
H3%	0.9	0.6	0.9	0.5
H5%	2.7	2.6	2.8	0.5
H7%	2.1	2.1	1.9	0.6


**Figure 5 and 6: Harmonic correction**

The Fluke 434 shows the harmonic distortion with and without the conditioner. The fifth harmonic is the biggest contributor to the current distortion. With the power conditioner turned on (right) note the significant reduction in the fifth harmonic. Current THD not displayed.

### Before



### After



**Figure 7 and 8: Harmonics affects on voltage and current**

These screens show phase A voltage and current with and without the power corrector. Note the effect of phase correction and harmonic cleanup on the current waveform.

## Why correct harmonics?

### What is it?

Total Harmonic Distortion (THD) is the sum of the contributions of all harmonics. Harmonic distortion is a normal consequence of a power system supplying electronic loads such as computers, business machines, electronic lighting ballasts, and control systems.

### What does it do?

Harmonic distortion can cause:

- High current to flow in neutral conductors.
- Motors and transformers to run hot, shortening their lives.
- Increased susceptibility to voltage sags, potentially causing spurious resets.
- Reduced efficiency of transformer—or, a larger unit is required to accommodate harmonics.
- Audible noise.

### How much does an incident cost?

The major costs are associated with shortened life of motors and transformers. If the equipment is part of production systems, income may be affected as well.

### Sample calculation

Assume the cost to replace a 100 KVA transformer is \$7000 including labor each year. Assume 8 hours of downtime each year with income loss of \$6000 per hour.

**Total Cost: \$7000 + (8 x \$6000) = \$55,000 annually**

### What to check?

Motors, transformers and neutral conductors serving electronic loads.

### How much is ok?

Voltage distortion (THD) should be investigated if it is over 5 % on any phase. Some current distortion (THD) is normal on any part of the system serving electronic loads. Monitor current levels and temperature at transformers to be sure that they are not overstressed. Neutral current should not exceed the capacity of the neutral conductor.



Maintenance Electrical Specialist Mark Newport using a Fluke 434 Power Quality Analyzer to measure, trend, and document the power factor and harmonics correction provided by the plant's new power correction system.

**Fluke.** *Keeping your world up and running.*

## Authorised distributor

### In Australia:

For customer service, call 1300-735-292

To fax an order, use 1800-067-639

To email an order, [ordersau@thermofisher.com](mailto:ordersau@thermofisher.com)

### In New Zealand:

For customer service, call 0800-933-966

To fax an order, use 0800-329-246

To email an order, [ordersnz@thermofisher.com](mailto:ordersnz@thermofisher.com)

**ThermoFisher**  
SCIENTIFIC